

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Information

Page Last Modified: 02/27/2023

Building Information

1. Name of school district

Rye Neck Union Free School District

2. SED District 8-Digit BEDS Code

66-19-01-03

3. Building Name:

F.E. Bellows Annex

4. SED 4-Digit Facility Code:

0005

5. Survey Inspection Date:

07/25/2022

6. Building 911 Address:

200 Carroll Avenue

7. City:

Mamaroneck

8. Zip Code:

10543

9. Certificate of Occupancy Status:

- A - Annual
- T - Temporary
- N - None

10. Certificate of Occupancy Expiration Date:

01/01/2024

10a. Is this a manufactured building? (Relocatable, modular, portable)

- Yes
- No

11. Have there been renovations or construction in the building during the past 12 months?

- Yes
- No

12. Was major construction/renovation work since 2015 conducted when school was in session?

- Yes
- No

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Information

Page Last Modified: 02/27/2023

13. Estimated capital construction expenses anticipated for this building through the 2024 calendar year excluding maintenance (to be answered after the building inspection is complete)

1,125,000.00

14. Overall building rating (to be answered after the building inspection is complete)

- Excellent
- Satisfactory
- Unsatisfactory
- Failing

15. Was overall building rating established after consultation with health and safety committee in accordance with Commissioner's Regulations 155.4(c)(1)?

- Yes
- No

16. A/E Firm Name:

LAN Associates, EPAS, LLP

17. A/E Firm Address:

252 Main Street, Goshen, NY 10924

18. A/E Firm Phone Number:

8456150350

19. E-mail:

danielle.farrell@lanassociates.com

20. A/E Name:

Danielle L. Farrell, AIA

21. A/E License #:

039812

Building Age, Gross Square Footage and Maintenance Staff

22. Building Age

	Year
Original Construction	1969
Addition #1	(No Response)
Addition #2	(No Response)
Addition #3	(No Response)
Addition #4	(No Response)
Addition #5	(No Response)
Addition #6	(No Response)

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Information

Page Last Modified: 02/27/2023

	Year
Addition #7	(No Response)
Addition #8	(No Response)
Addition #9	(No Response)

23. Square feet of construction

	Sq Feet
Original construction	12,420.00
Addition #1	(No Response)
Addition #2	(No Response)
Addition #3	(No Response)
Addition #4	(No Response)
Addition #5	(No Response)
Addition #6	(No Response)
Addition #7	(No Response)
Addition #8	(No Response)
Addition #9	(No Response)

24. Gross square ft. of Building as currently configured:

12,420

25. Number of Floors:

1

26. How many full-time and part-time custodians are employed at the school (or work in the building)?

	Count Employees
Full-time custodians:	0
Part-time custodians:	0
Totals:	0

Building Ownership and Occupancy Status

27. Building Ownership (check one):

- Owned and used by district
- Owned by District and leased to non-district entity
- Owned by District, part used by district, part leased to non-district entity
- Owned by non-district entity and leased to district

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Information

Page Last Modified: 02/27/2023

28. For which of the following purposes is the building currently used? (check all that apply)

- Used for student instructional purposes
- Used for district administration
- Used for other district purposes
- Used by other organization(s)

Building Users

29. How many students were registered to receive instruction in this building as of the last year? (If none, enter "0") and skip to "Program Spaces" section. (Do not include evening class students)

0

30. Of these registered students, how many receive most of their instruction in:

	Quantity
Permanent instructional spaces (i.e., regular classrooms)	0
Temporary instructional spaces (i.e., portable or demountable classrooms) attached to the building	0
Non-instructional spaces used as instructional spaces	0

31. If the answer is greater than zero, which types of non-instructional spaces were being used for instructional purposes on October 1, 2019? (check all that apply)

- Cafeteria
- Gymnasium
- Administrative Spaces
- Library
- Lobby
- Stairwell
- Storage space
- Other (please describe)
- None

32. Grades Housed

- Pre-K
- Kindergarten
- 1st
- 2nd
- 3rd
- 4th
- 5th
- 6th
- 7th
- 8th
- 9th
- 10th
- 11th
- 12th
- N/A (none)

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Information

Page Last Modified: 02/27/2023

33. For how many instructional days during the school year prior to the BCS assigned year (July 1 through June 30) was the building closed due to facilities failures, system malfunctions, structural problems, fire, etc? (if none, enter "0")

0

34. Is the building used for instructional purposes in the summer?

Yes

No

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Program Spaces

Page Last Modified: 02/27/2023

Program Spaces

35. Number of instructional classrooms:

2

36. Gross square footage of all instructional classrooms (combined):

1,770.00

37. Other spaces provided:

- | | | |
|--|---|---|
| <input type="checkbox"/> a. N/A (none) | <input type="checkbox"/> j. Health Office | <input type="checkbox"/> s. Resource Rooms |
| <input type="checkbox"/> b. Administration | <input type="checkbox"/> k. Home & Careers | <input type="checkbox"/> t. Science Labs |
| <input checked="" type="checkbox"/> c. Art | <input type="checkbox"/> l. Kitchen | <input type="checkbox"/> u. Special Education |
| <input type="checkbox"/> d. Audio Visual | <input type="checkbox"/> m. Large Group Instruction | <input type="checkbox"/> v. Swimming Pool |
| <input type="checkbox"/> e. Auditorium | <input type="checkbox"/> n. Library | <input type="checkbox"/> w. Teacher Resource |
| <input checked="" type="checkbox"/> f. Cafeteria | <input type="checkbox"/> o. Multipurpose Rooms | <input type="checkbox"/> x. Technology/Shop |
| <input type="checkbox"/> g. Computer Room | <input checked="" type="checkbox"/> p. Music | <input type="checkbox"/> y. Other (please describe) |
| <input type="checkbox"/> h. Guidance | <input type="checkbox"/> q. Pre-K | |
| <input type="checkbox"/> i. Gymnasium | <input type="checkbox"/> r. Remedial Rooms | |

37a. Describe other spaces

(No Response)

Space Adequacy

38. Rating of space adequacy:

- Good
- Fair
- Poor

38a. Enter comments:

(No Response)

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Site Utilities

Page Last Modified: 02/27/2023

SITE UTILITIES

39. Water (H)

- Yes
- No

39a. Type of Service:

- Municipal or Utility provided
- Well
- Other

39b. Types of water service piping

- Iron
- Galvanized
- Copper
- Lead
- PVC
- Other
- N/A (None)

39c. Overall condition of water service piping

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

39d. Year of Last Major Reconstruction/Replacement:

2007

39e. Expected Remaining Useful Life (Years):

20

39f. Cost to Reconstruct/Replace \$:

(No Response)

39g. Comments:

FED FROM MAIN BUILDING

40. Site Sanitary (H)

- Yes
- No

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Site Utilities

Page Last Modified: 02/27/2023

40a. Type of Service:

- Municipal or utility sewer
- Site septic
- Other

40b. Condition:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

40c. Year of Last Major Reconstruction/Replacement:

1997

40d. Expected Remaining Useful Life (Years):

20

40e. Cost to reconstruct/Replace \$:

(No Response)

40f. Comments:

FED FROM MAIN BUILDING

41. Site Gas

- Yes
- No

41a. Type of gas service:

- Natural Gas
- Liquid Petroleum

41b. Condition:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

41c. Year of Last Major Reconstruction/Replacement;

1998

41d. Expected Remaining Useful Life (Years):

20

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Site Utilities

Page Last Modified: 02/27/2023

41e. Cost to Reconstruct/Replace \$:

(No Response)

41f. Comments:

FED FROM MAIN BUILDING

42. Site Fuel Oil

Yes

No

43. Site Electrical, Including Exterior Distribution

Yes

No

43a. Service Provider:

Municipal or utility provided

Self-Generated

Other

N/A

43b. Type of Service:

Above Ground

Below Ground

N/A

43c. Condition:

Excellent

Satisfactory

Unsatisfactory

Non-Functioning

Critical Failure

43d. Year of Last Major Reconstruction/Replacement:

2013

43e. Expected Remaining Useful Life (Years):

15

43f. Cost to Reconstruct/Replace \$:

69,436.00

43g. Comments:

Upgrade electrical service for future expansion

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Site Utilities

Page Last Modified: 02/27/2023

SITE FEATURES

44. Closed Drainage Pipe Stormwater Management System

44a. Does this facility have a closed pipe system?

- Yes
- No

44b. Condition:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

44c. Year of Last Major Reconstruction/Replacement:

2018

44d. Expected Remaining Useful Life (Years):

20

44e. Cost to Reconstruct/Replace \$:

0.00

44f. Comments:

(No Response)

45. Open Drainage Pipe Stormwater Management System

45a. Does this facility have an open stormwater system (ditch)?

- Yes
- No

46. Catch Basins/Drop Inlets/Manholes

46a. Does this facility have catch basins/drop inlets/manholes?

- Yes
- No

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Site Utilities

Page Last Modified: 02/27/2023

46b. Condition:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

46c. Year of Last Major Reconstruction/Replacement:

2013

46d. Expected Remaining Useful Life (Years):

15

46e. Cost to Reconstruct/Replace \$:

0.00

46f. Comments:

(No Response)

47. Culverts

47a. Does this facility have culverts?

- Yes
- No

48. Outfalls

48a. Does this facility have outfalls?

- Yes
- No

48b. Condition:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

48c. Year of Last Major Reconstruction/Replacement:

2006

48d. Expected Remaining Useful Life (Years):

10

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Site Utilities

Page Last Modified: 02/27/2023

48e. Cost to Reconstruct/Replace \$:

0.00

48f. Comments:

(No Response)

49. Infiltration Basins/Chambers

49a. Does this facility have infiltration basins/chambers?

- Yes
- No

50. Retention Basins

50a. Does this facility have retention basins?

- Yes
- No

51. Wetponds

51a. Does this facility have wetponds?

- Yes
- No

52. Manufactured Stormwater Proprietary Units

52a. Does this facility have proprietary units?

- Yes
- No

53. Point of Outfall Discharge: (check all that apply)

- Municipal storm sewer system
- Combined sewer system
- Surface Water
- On-site recharge
- Other (describe)
- Not Applicable

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Site Utilities

Page Last Modified: 02/27/2023

54. Outfall Reconnaissance Inventory

Were all stormwater outfalls inspected during dry weather for signs of non-stormwater discharge?

- Yes
- No
- Not Applicable

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Other Site Features

Page Last Modified: 02/27/2023

SITE FEATURES

55. Pavement (Roadways and Parking Lots)

- Yes
- No

55a. Type: (check all that apply)

- Concrete
- Asphalt
- Gravel
- Other

55b. Condition:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

55c. Year of Last Major Reconstruction/Replacement:

2006

55d. Expected Remaining Useful Life (Years):

15

55e. Cost to Reconstruct/Replace \$:

191,500.00

55f. Comments:

Repave play areas at east side of annex building. Reseal asphalt paving area at north side of annex building.

56. Sidewalks

- Yes
- No

56a. Type: (check all that apply)

- Asphalt
- Concrete
- Gravel
- Paver
- Other

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Other Site Features

Page Last Modified: 02/27/2023

56b. Condition:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

56c. Year of Last Major Reconstruction/Replacement:

2013

56d. Expected Remaining Useful Life (Years):

15

56e. Cost to Reconstruct/Replace \$:

20,000.00

56f. Comments:

Replace east canopy concrete sidewalk.

57. Playgrounds and Playground Equipment

- Yes
- No

57a. Condition:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

57b. Year of Last Major Reconstruction/Replacement:

2014

57c. Expected Remaining Useful Life (Years):

15

57d. Cost to Reconstruct/Replace \$:

0.00

57e. Comments:

(No Response)

58. Athletic Fields and Play Fields

- Yes
- No

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Other Site Features

Page Last Modified: 02/27/2023

58a. Condition:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

58b. Year of Last Major Reconstruction/Replacement:

2014

58c. Expected Remaining Useful Life (Years):

20

58d. Cost to Reconstruct/Replace \$:

55,000.00

58e. Comments:

Resurface Infield baseball diamond. Replace all nylon netting at west side of field with chainlink fence.

58f. Does the facility have synthetic turf field(s)

- Yes
- No

58f.1 If Yes, how many synthetic turf fields?

(No Response)

58f.2 Expected Remaining Useful Life of Synthetic Turf Field(s):

(No Response)

58f.3 Type of synthetic turf field infill:

(No Response)

59. Exterior Bleachers / Stadiums

- Yes
- No

60. Related Structures (such as Press Boxes, Dugouts, Climbing Walls, etc.)

- Yes
- No

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Other Site Features

Page Last Modified: 02/27/2023

60a. Condition:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

60b. Year of Last Major Reconstruction/Replacement:

2014

60c. Expected Remaining Useful Life (Years):

15

60d. Cost to Reconstruct/Replace \$:

800.00

60e. Comments:

Replenish wood mulch in play area at east side of annex building.

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Structure

Page Last Modified: 02/17/2023

Building Structure

61. Foundation (S)

61a. Type (check all that apply):

- Reinforced Concrete
- Masonry on Concrete Footing
- Other (specify)

61a1. If "Other" please specify

(No Response)

61b. Evidence of structural concerns (check all that apply):

- Structural Cracks
- Heaving/Jacking
- Decay/Corrosion
- Water Penetration
- Unsupported Ends
- Other
- None

61c. Condition:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

61d. Year of Last Major Reconstruction/Replacement:

1969

61e. Expected Remaining Useful Life (Years):

20

61f. Cost to Reconstruct/Replace \$:

0.00

61g. Comments:

(No Response)

62. Piers (S)

- Yes
- No

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Structure

Page Last Modified: 02/17/2023

62f. Cost to Reconstruct/Replace \$:

(No Response)

63. Columns (S)

Type (check all that apply):

- Concrete
- Masonry
- Steel
- Stone
- Wood
- Other (specify)
- N/A (None)

63.1. If "Other" please specify

(No Response)

63a. Evidence of structural concerns (check all that apply)

- Structural Cracks
- Heaving/Jacking
- Decay/Corrosion
- Water Penetration
- Unsupported Ends
- Other
- None

63b. Condition:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

63c. Year of Last Major Reconstruction/Replacement

1969

63d. Expected Remaining Useful Life (Years):

20

63e. Cost to Reconstruct/Replace \$:

0.00

63f. Comments:

(No Response)

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Structure

Page Last Modified: 02/17/2023

64. Footings (S)

Type (check all that apply):

- Concrete
- Other (specify)

64a. Evidence of structural concerns (check all that apply)

- Structural Cracks
- Heaving/Jacking
- Decay/Corrosion
- Water Penetration
- Unsupported Ends
- Other (specify)
- None

64.a1. If "Other" please specify

(No Response)

64b. Condition:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

64c. Year of Last Major Reconstruction/Replacement

1969

64d. Expected Remaining Useful Life (Years):

20

64e. Cost to Reconstruct/Replace \$:

0

64f. Comments:

(No Response)

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Structure

Page Last Modified: 02/17/2023

65. Structural Floors (S)

65a. Type (check all that apply):

- Concrete Deck on Wood Structure
- Concrete/Metal Deck/Metal Joists
- Cast in Place Concrete Structural System
- Precast Concrete Structural System
- Reinforced Concrete Slab on Grade
- Wood Deck on Wood Trusses
- Wood Deck on Wood Joists
- Other (specify)

65b. Evidence of Structural Concerns with Floor Support System (Beams/Joists/Trusses, etc.) (check all that apply):

- Structural Cracks
- Unsupported Ends
- Rot/Decay/Corrosion
- Deflection
- Seriously Damaged/Missing Components
- Other Problems
- None

65b.1 Describe Other Problems:

(No Response)

65c. Evidence of Structural Concerns with Structural Floor Deck (check all that apply):

- Cracks
- Deflection
- Rot/Decay/Corrosion
- None

65d. Overall Condition of Structural Floors:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

65e. Year of Last Major Reconstruction/Replacement:

1969

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Structure

Page Last Modified: 02/17/2023

65f. Expected Remaining Useful Life (Years):

20

65g. Cost to Reconstruct/Replace \$:

0.00

65h. Comments:

(No Response)

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Envelope

Page Last Modified: 02/27/2023

BUILDING ENVELOPE

66. Exterior Walls/Columns (S)

66a. Material (check all that apply):

- Aluminum/Glass Curtain Wall
- Brick
- Concrete
- Composite Insulated Panels
- Masonry
- Steel
- Wood
- Other (specify)

66b. Evidence of Structural Concerns with Support System (columns, base plates, connections, etc.)

(check all that apply):

- Structural Cracks
- Rot/Decay/Corrosion
- Other Problems
- None

66b.1 Describe Other Problems:

(No Response)

66c. Evidence of Concerns with Exterior Cladding (check all that apply):

- Cracks/Gaps
- Inadequate Flashing
- Efflorescence
- Moisture Penetration
- Rot/Decay/Corrosion
- Other Problems
- None

66c.1 Describe Other Problems:

(No Response)

66d. Overall Condition of Exterior Walls/Columns:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Envelope

Page Last Modified: 02/27/2023

66e. Year of Last Major Reconstruction/Replacement:

1969

66f. Expected Remaining Useful Life (Years):

20

66g. Cost to Reconstruct/Replace \$:

0.00

66h. Comments:

(No Response)

67. Chimneys (S)

Yes

No

68. Parapets (S)

Yes

No

69. Exterior Doors

69a. Overall Condition of Exterior Door Units:

Excellent

Satisfactory

Unsatisfactory

Non-Functioning

Critical Failure

69b. Do any exterior doors have magnetic locking devices?

Yes

No

69c. Safety/Security features are adequate?

Yes

No

69d. Year of Last Major Reconstruction/Replacement:

2004

69e. Expected Remaining Useful Life (Years):

10

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Envelope

Page Last Modified: 02/27/2023

69f. Cost to Reconstruct/Replace \$:

50,000.00

69g. Comments:

Replace doors.

70. Exterior Steps, Stairs, Ramps (S)

- Yes
- No

71. Fire Escapes (S)

71a. Does This Facility Have One or More Fire Escapes?

- Yes
- No

72. Windows

- Yes
- No

72a. Window Material: (check all that apply)

- Aluminum
- Steel
- Vinyl
- Solid Wood
- Wood w/ External Cladding System
- Other

72a1. If "Other" please specify

(No Response)

72b. Overall Condition of Windows:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Envelope

Page Last Modified: 02/27/2023

72c. All Rescue Windows are Operable:

- Yes
- No
- N/A

72d. Year of Last Major Reconstruction/Replacement:

1997

72e. Expected Remaining Useful Life (Years):

10

72f. Cost to Reconstruct/Replace \$:

0.00

72g. Comments:

(No Response)

73. Roof and Skylights (S)

- Yes
- No

73a. Type of roof construction (check all that apply):

- Concrete on metal deck on metal trusses/joists
- Concrete (poured or plank) on concrete beams
- Gypsum (poured or plank) on metal trusses/joists
- Metal deck on metal trusses/joists
- Wood deck on wood trusses/joists
- Wood deck on metal trusses/joists
- Tectum on metal trusses/joists
- Other (describe below)

73a.1 Other roof construction type:

(No Response)

73b. Type of roofing material (check all that apply):

- Single-ply membrane
- Built-up
- Asphalt shingle
- Pre-formed metal
- IRMA
- Slate
- Fluid applied seamless surfacing
- Other (describe below)

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Envelope

Page Last Modified: 02/27/2023

73b.1 Other roofing material:

(No Response)

73c. Evidence of structural concerns with roof support system (beams/joists/trusses, etc.) (check all that apply):

- Structural cracks
- Unsupported ends
- Rot/Decay/Corrosion
- Deflection
- Seriously damaged/missing components
- Other concerns (describe)
- None

73c.1 Describe other concerns:

(No Response)

73d. Evidence of structural concerns with roof deck (check all that apply):

- Cracks
- Deflection
- Rot/Decay/Corrosion
- None

73e. Does this facility have skylights?

- Yes
- No

73f. Skylight material (check all that apply):

- Plastic
- Glass
- Other
- N/A

73g. Overall condition of skylights:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Envelope

Page Last Modified: 02/27/2023

73h. Evidence of concerns with roofing, skylights, flashings, and drains (check all that apply):

- Failures/Splits/Cracks
- Rot/Decay/Corrosion
- Inadequate flashing/curbs/pitch pockets
- Inadequate or poorly functioning roof drains
- Evidence of water penetration/active leaks
- Other (specify)
- None

73h.1 Specify other concerns:

(No Response)

73i. Overall Condition of Roof and Skylights:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

73j. Year of Last Major Reconstruction/Replacement:

2019

73k. Expected Remaining Useful Life (Years):

15

73l. Cost to Reconstruct/Replace \$:

0.00

73m. Comments:

(No Response)

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Interiors

Page Last Modified: 02/27/2023

BUILDING INTERIOR

74. Interior Bearing Walls and Fire Walls (S)

- Yes
- No

74a. Overall condition of interior bearing walls and fire walls:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-functioning
- Critical Failure

74b. Year of Last Major Reconstruction/Replacement:

1969

74c. Expected Remaining Useful Life (Years):

15

74d. Cost to Reconstruct/Replace \$:

9,600.00

74e. Comments:

Repair base course of CMU walls along west and south exterior walls

74.f Regulatory

Have design professionals provided inventory of construction regulated under BCNYS Ch7, including assessment of their condition and maintenance, as required by NYSFC Ch7 and NYSPMC 703? This includes, but is not limited to:

[check each item provided to the district]

- Fire-resistance rated assemblies;
- Smoke barriers and smoke partitions;
- Penetrations, joints, voids, door
- Assessment of Ch7 regulated assembly either damaged, altered, breached, or penetrated;
- Confirmation of compliant repair or protection of Ch7 regulated assembly either damaged, altered, breached, or penetrated;
- Other:

74.f Other:

(No Response)

75. Other Interior Walls

- Yes
- No

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Interiors

Page Last Modified: 02/27/2023

75a. Overall condition of other interior walls:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

75b. Year of Last Major Reconstruction/Replacement:

1969

75c. Expected Remaining Useful Life (Years):

15

75d. Cost to Reconstruct/Replace \$:

(No Response)

75e. Comments:

(No Response)

76. Carpet

- Yes
- No

76a. Where located (check all that apply):

- Classrooms
- Corridors
- Offices
- Assembly Spaces (Auditorium, Gym, Play Room, etc.)
- Other Areas

76b. Condition:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

76c. Year of Last Major Reconstruction/Replacement:

2004

76d. Expected Remaining Useful Life (Years):

5

76e. Cost to Reconstruct/Replace \$:

16,000.00

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Interiors

Page Last Modified: 02/27/2023

76f. Comments:

Replace carpet in Music Room

77. Resilient Tiles or Sheet Flooring

- Yes
- No

77a. Where located (check all that apply):

- Classrooms
- Corridors
- Offices
- Assembly Spaces (Auditorium, Gym, Play Room, etc.)
- Other Areas

77b. Overall condition of resilient tiles or sheet flooring:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

77c. Year of Last Major Reconstruction/Replacement:

2004

77d. Expected Remaining Useful Life (Years):

5

77e. Cost to Reconstruct/Replace \$:

19,400.00

77f. Comments:

Replace VCT in Art Room

78. Hard Flooring (concrete; ceramic tile; stone; etc)

- Yes
- No

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Interiors

Page Last Modified: 02/27/2023

78a. Where located (check all that apply):

- Classrooms
- Corridors
- Offices
- Assembly Spaces (Auditorium, Gym, Play Room, etc.)
- Kitchen
- Locker Rooms/Toilet Rooms
- Other Areas

78b. Overall condition of hard flooring:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

78c. Year of Last Major Reconstruction/Replacement:

1969

78d. Expected Remaining Useful Life (Years):

10

78e. Cost to Reconstruct/Replace \$:

(No Response)

78f. Comments:

(No Response)

79. Wood Flooring

- Yes
- No

80. Ceilings (H)

- Yes
- No

80a. Overall condition of ceilings:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Interiors

Page Last Modified: 02/27/2023

80b. Year of Last Major Reconstruction/Replacement:

2004

80c. Expected Remaining Useful Life (Years):

10

80d. Cost to Reconstruct/Replace \$:

1,500.00

80e. Comments:

Repair gap in ceiling above east exterior door from the Art and Music Rooms

81. Lockers

Yes

No

81d. Cost to Reconstruct/Replace \$:

(No Response)

82. Interior Doors

Yes

No

82a. Overall condition of interior door units:

Excellent

Satisfactory

Unsatisfactory

Non-Functioning

Critical Failure

82b. Overall condition of interior door hardware:

Excellent

Satisfactory

Unsatisfactory

Non-Functioning

Critical Failure

82c. Year of Last Major Reconstruction/Replacement:

2004

82d. Expected Remaining Useful Life (Years):

5

82e. Cost to Reconstruct/Replace \$:

63,000.00

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Building Interiors

Page Last Modified: 02/27/2023

82f. Comments:

Replace interior doors

83. Interior Stairs (H)

Yes

No

84. Elevator, Lift, and Escalators (H)

Yes

No

85. Swimming Pool and Swimming Pool Systems (H)

Yes

No

86. Interior Bleachers

Yes

No

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

HVAC Systems

Page Last Modified: 02/27/2023

HVAC Systems

87. Heat Generating Systems (H)

- Yes
- No

87a. Heat generation source (check all that apply):

- Biomass
- Boiler / Hot Water
- Boiler / Steam
- Cogeneration Plant
- Electric
- Furnace / Forced Air
- Geothermal
- Heat Pump
- Unit Ventilation
- Other (describe below)

87a.1 Other heat generation source:

(No Response)

87b. Overall condition of heat generating systems:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

87c. Year of Last Major Reconstruction/Replacement:

2003

87d. Expected Remaining Useful Life (Years):

5

87e. Cost to Reconstruct/Replace \$:

310,000.00

87f. Comments:

REPLACE 15-TON ROOFTOP UNIT

88. Ventilation System (exhaust fans, etc) (H)

- Yes
- No

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

HVAC Systems

Page Last Modified: 02/27/2023

88a. Type of ventilation system (check all that apply)

<input type="checkbox"/> Natural ventilation	<input type="checkbox"/> Heat pump
<input type="checkbox"/> Central system	<input type="checkbox"/> Split system/ variable refrigerant
<input type="checkbox"/> Energy recovery ventilator	<input type="checkbox"/> Powered relief air system
<input checked="" type="checkbox"/> Rooftop units	<input type="checkbox"/> Gravity/barometric relief
<input type="checkbox"/> Unitary (UVs, FC/BC, PTAC)	<input checked="" type="checkbox"/> Other (specify)
<input type="checkbox"/> Forced air furnace	

88b. If "Other" please specify here

EXHAUST FANS

88c. Overall condition of ventilation systems

Excellent

Satisfactory

Unsatisfactory

Non-functioning

Critical Failure

88d. Year of last major reconstruction/replacement

2003

88e. Expected remaining useful life (years):

10

88f. Cost to reconstruct/replace \$:

310,000

88g. Comments

REPLACE 15-TON ROOFTOP UNIT

89. Mechanical Cooling / Air-Conditioning Systems

Yes

No

89a. Types of mechanical cooling

Chiller/chilled water

Geothermal

Air cooled

Water cooled

DX/Split system

Heat pump

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

HVAC Systems

Page Last Modified: 02/27/2023

89b. Overall condition of cooling/air-conditioning systems:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

89c. Year of Last Major Reconstruction/Replacement:

2003

89d. Expected Remaining Useful Life (Years):

5

89e. Cost to Reconstruct/Replace \$:

310,000.00

89f. Comments:

REPLACE 15-TON ROOFTOP UNIT

90. Piped Heating and Cooling Distribution Systems: Piping, Pumps, Radiators, Convectors, Traps, Insulation, etc. (H)

- Yes
- No

91. Ducted Heating and Cooling Distribution Systems: Ductwork, Control Dampers, Fire/Smoke Dampers, VAVs, Insulation, etc. (H)

- Yes
- No

91a. Overall condition of ducted heating and cooling distribution systems:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

91b. Year of Last Major Reconstruction/Replacement:

1997

91c. Expected Remaining Useful Life (Years):

10

91d. Cost to Reconstruct/Replace \$:

50,000.00

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

HVAC Systems

Page Last Modified: 02/27/2023

91e. Comments:

ADD VARIABLE AIR VOLUME (VAV) BOXES

92. HVAC Control Systems (H)

- Yes
- No

92a. Type of control system

- Pneumatic
- Electric
- Digital Direct Control (DDC)
- Web based DDC

92b. Overall condition of control systems:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

92c. Year of Last Major Reconstruction/Replacement:

1997

92d. Expected Remaining Useful Life (Years):

10

92e. Cost to Reconstruct/Replace \$:

25,000.00

92f. Comments:

UPDATE CONTROLS TO ADD VAV BOXES AND ROOFTOP UNIT REPLACEMENT

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Plumbing Systems

Page Last Modified: 02/17/2023

PLUMBING

93. Water Supply System (H)

- Yes
- No

93a. Types of pipes (check all that apply):

- Asbestos/transite
- Copper
- Galvanized
- Iron
- Lead
- PVC/CPVC/PEX/Plastic
- Other (specify)

93b. If "Other" please specify here

(No Response)

93c. Overall condition of water supply system:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

93d. Year of Last Major Reconstruction/Replacement:

1997

93e. Expected Remaining Useful Life (Years):

20

93f. Cost to Reconstruct/Replace \$:

(No Response)

93g. Comments:

(No Response)

94. Sanitary System (H)

- Yes
- No

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Plumbing Systems

Page Last Modified: 02/17/2023

94a. Types of pipes (check all that apply):

- Iron
- Galvanized
- Copper
- Glass/ceramic
- PVC/CPVC/ABS/poly propylene/plastic
- Lead
- Other (specify)

94a1. If "Other" please specify

(No Response)

94b. Types of special sanitary systems (Check all that apply)

- Acid waste and vent
- Grease interceptor
- Oil separator
- Pumping station
- Sediment trap
- Septic tank
- Waste water treatment plant

94c. Overall condition of sanitary system:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

94d. Year of Last Major Reconstruction/Replacement:

1997

94e. Expected Remaining Useful Life (Years):

20

94f. Cost to Reconstruct/Replace \$:

(No Response)

94g. Comments:

(No Response)

95. Storm Water Drainage System (H)

- Yes
- No

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Plumbing Systems

Page Last Modified: 02/17/2023

95a. Types of pipes (check all that apply)

- Iron
- Galvanized
- Copper
- Lead
- Plastic
- Other

95a1. If "Other" please specify

(No Response)

95b. Overall condition of storm water drainage system

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

95c. Year of Last Major Reconstruction/Replacement

1969

95d. Expected Remaining Useful Life (Years)

10

95e. Cost to Reconstruct/Replace \$:

(No Response)

95f. Comments:

(No Response)

96. Hot Water Heaters (H)

- Yes
- No

96a. Type of fuel (check all that apply):

- Oil
- Natural Gas
- Electricity
- Propane
- Other (specify)

96b. If "Other" please specify

(No Response)

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Plumbing Systems

Page Last Modified: 02/17/2023

96c. Overall condition of hot water heaters:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

96d. Year of Last Major Reconstruction/Replacement:

2018

96e. Expected Remaining Useful Life (Years):

10

96f. Cost to Reconstruct/Replace \$:

(No Response)

96g. Comments:

(No Response)

97. Plumbing Fixtures (H)

- Yes
- No

97a. Overall condition of plumbing fixtures (including toilets, urinals, lavatories, sinks, showers, etc):

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

97b. Year of Last Major Reconstruction/Replacement:

1997

97c. Expected Remaining Useful Life (Years):

20

97d. Cost to Reconstruct/Replace \$:

(No Response)

97e. Comments:

(No Response)

98. Water Outlets/Taps for Drinking/Cooking Purposes (H)

- Yes
- No

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Plumbing Systems

Page Last Modified: 02/17/2023

98a. Overall condition of water outlets/taps (drinking fountains, bubblers, bottle fillers, kitchen prep, ice machines, etc).

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

98b. Year of last major reconstruction/replacement:

1997

98c. Expected remaining useful life (years):

20

98d. Cost to reconstruct/replace \$:

(No Response)

98e. Comments

(No Response)

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Fire Suppression Systems

Page Last Modified: 02/17/2023

Fire Suppression Systems

99. Fire Suppression System (H)

Yes

No

100. Kitchen Hoods (H)

Yes

No

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Electrical Systems

Page Last Modified: 02/27/2023

ELECTRICAL SYSTEMS

101. Electrical Power Distribution System (H)

- Yes
- No

101a. Electrical supply meets current needs:

- Yes
- No

101b. Condition of electrical power distribution system:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-Functioning
- Critical Failure

101c. Year of last major reconstruction/replacement?

1998

101d. Expected remaining useful life (years):

10

101e. Cost to reconstruct/replace:

69,436.00

101f. Comments:

Replace outdate panelboards

102. Lighting Fixtures (H)

- Yes
- No

102a. Condition of lighting figures:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-functioning
- Critical failure

102b. Year of last major reconstruction/replacement:

2004

102c. Expected remaining useful life (years):

5

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Electrical Systems

Page Last Modified: 02/27/2023

102d. Cost to reconstruct/replace:

118,042

102e. Comments

Upgrade light fixtures throughout to include exterior building mounted fixtures to be LED

103. Emergency/ Exit Lighting Systems (H):

Yes

No

103a. Overall condition of emergency/exit lighting systems:

Excellent

Satisfactory

Unsatisfactory

Non-functioning

Critical failure

103b. Year of last major reconstruction/replacement:

2007

103c. Expected remaining useful life (years):

10

103d. Cost to reconstruct/replace:

27,051

103e. Comments

Upgrade emergency fixtures to LED. Install exit signs.

104. Emergency or standby power system (H)

Yes

No

105. Fire Alarm Systems (manual, automatic fire detection, and notification appliances) (H)

Yes

No

105a. Overall condition of fire alarm system:

Excellent

Satisfactory

Unsatisfactory

Non-functioning

Critical failure

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Electrical Systems

Page Last Modified: 02/27/2023

105b. Year of last major reconstruction/replacement:

2007

105c. Expected remaining useful life (years):

10

105d. Cost to reconstruct/replace:

(No Response)

105e. Comments

(No Response)

106. Carbon Monoxide Alarm System (H)

Yes

No

107. Communcation Systems (H)

Yes

No

107a. Type of communication system (check all that apply)

- Public Address
- Phones (VOIP)
- Phones (Cellular)
- Phones (other)
- Mass Notification
- Emergency voice communication fire alarm system
- Lockdown notification system
- Other (eg. radio) (describe below)

107b. If "Other" please describe

Wired phone lines

107c. Communication systems are adequate:

Yes

No

107d. Condition of communication system:

- Excellent
- Satisfactory
- Unsatisfactory
- Non-functioning
- Critical failure

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Electrical Systems

Page Last Modified: 02/27/2023

107e. Year of last major reconstruction/replacement:

1997

107f. Expected remaining useful life:

10

107g. Cost to replace/reconstruct:

(No Response)

107h. Comments

(No Response)

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Student Transportation Facilities

Page Last Modified: 02/17/2023

Student Transportation Facilities

108. Is this building a transportation facility

Yes

No

109. Does this facility have a fuel dispensing system?

Yes

No

110. Does this facility have vehicle lifts

Yes

No

111. Does this facility have a bus wash system?

Yes

No

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Accessibility

Page Last Modified: 02/17/2023

ACCESSIBILITY

112. Exterior Accessible Route to Building (H)

People with disabilities should be able to arrive on site, approach the building, and enter as freely as everyone else. At least one route of travel should be safe and accessible for everyone, including people with disabilities. This route must include handicapped parking, curb cuts, ramps, and automatic door operators as necessary to enter the building.

Is there an accessible exterior route as specified above?

- Yes
- No

112a. Features provided for exterior accessible route (check all that apply)

- Curb ramps
- Exterior ramps
- Handicap parking

112b. Cost of improvements needed to provide exterior accessible route to building \$:

(No Response)

112c. Comment

(No Response)

113. Is there an exterior accessible route to recreational facilities?

- Yes
- No

113a. Cost of improvements to provide exterior accessible route(s) to recreational facilities \$:

(No Response)

113b. Comments

(No Response)

114. Exterior recreational facilities that are on an accessible route and meet accessibility standards (check all that apply)

- Playground and play equipment
- Playfield(s)
- Athletic Field(s)
- Exterior Bleachers
- Bathroom Facilities
- Concession Stand

114a. Cost of improvements to provide exterior accessible recreational facilities \$:

(No Response)

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Accessibility

Page Last Modified: 02/17/2023

114b. Comments

(No Response)

115. Interior Accessible Route, Access to Goods and Services, and Restroom Facilities (H)

The layout of the building should allow people with disabilities to obtain materials or services and use the facilities without assistance. This should include access to general purpose and specialized classrooms, public assembly spaces (such as libraries, gymnasiums, auditoriums), nurse's office, main office, and restroom facilities. Services include drinking fountains, telephones, and other amenities.

Is there an interior accessible interior route as specified above?

Yes

No

115a. Cost of improvements needed to provide interior accessible route(s) as specified above \$:

(No Response)

115b. Comments

(No Response)

116. Does this facility have interior spaces that meet accessibility standards (check all that apply)

Classrooms

Labs (science, art, technology, etc)

Shops

Main Office

Health Office

Gymnasium

Cafeteria

Auditorium

Stage

Restrooms on each floor

116a. Cost of improvements to provide interior spaces that meet accessibility standards \$:

155,000

116b. Comments

Reconstruct restrooms to be ADA, Provide ADA Signage

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Environment/Comfort/Health

Page Last Modified: 02/26/2023

ENVIRONMENT/COMFORT/HEALTH

117. General Appearance

117a. Overall Rating:

- Good
- Fair
- Poor

117b. Comments:

(No Response)

118. Cleanliness (H)

118a. Overall Rating:

- Good
- Fair
- Poor

118b. Comments:

(No Response)

119. Are there walk off mats; grills in the entryway?

- Yes
- No

119a. If yes: at least 6 feet long?

- Yes
- No

120. Is there noise in classrooms from HVAC units, traffic, etc. that may impact education? (H)

- Yes
- No

121. Lighting Quality (H):

121a. Types of lighting in general purpose classrooms (check all that apply):

- Daylight (natural)
- Not full spectrum
- Full spectrum
- LED
- Flourescent
- Other (describe)

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Environment/Comfort/Health

Page Last Modified: 02/26/2023

121b. Are there blinds in the classroom to prevent glare?

- Yes
- No

121c. Overall Rating:

- Good
- Fair
- Poor

121d. Comments:

(No Response)

122. Evidence of Vermin (H)

122a. Is there evidence of active infestations of...(check all that apply)?

- Rodents
- Wood-boring or Wood-eating Insects
- Cockroaches
- Other Vermin
- None

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Indoor Air Quality

Page Last Modified: 02/17/2023

Indoor Air Quality

123. Mold (H)

123a. Is there visible mold or moldy odors?

- Yes
- No

123b. Are any surfaces constructed of any of the following materials?

- Paper-faced or gypsum products
- Cellulose products (typically ceiling tiles)
- Not Applicable

123c. Is there evidence of water intrusion?

- Yes
- No

123d. Estimated cost of necessary improvements \$:

(No Response)

123e. Comments:

(No Response)

124. Humidity/Moisture (H)

124a. Overall rating of humidity/moisture condition in building:

- Good
- Fair
- Poor

124b. Are any of the following found in/or around classroom areas (check all that apply)?

- Active leaks in roof
- Active leaks in plumbing
- Moisture condensation
- Visible stains or water damage
- None

124c. Are any of the following found in/or around other areas (check all that apply)?

- Active leaks in roof
- Active leaks in plumbing
- Moisture condensation
- Visible stains or water damage
- None

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Indoor Air Quality

Page Last Modified: 02/17/2023

125. Ventilation: fresh air intake locations, air filters, etc. (H)

125a. Are fresh air intakes near the bus loading, truck delivery, or garbage storage/disposal areas?

- Yes
- No

125b. Is there accumulated dirt, dust or debris around fresh air intakes?

- Yes
- No

125c. Are fresh air intakes free of blockage?

- Yes
- No

125d. Is accumulated dirt, dust or debris in ductwork?

- Yes
- No

125e. Are dampers functioning as designed?

- Yes
- No

125f. Condition of air filters:

- Good
- Fair
- Poor

125g. Outside air is adequate for occupant load:

- Yes
- No

125h. Rating of ventilation/indoor air quality:

- Good
- Fair
- Poor

125i. Comments:

(No Response)

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Indoor Air Quality

Page Last Modified: 02/17/2023

126. Indoor Air Quality (IAQ) Plan (H)

126a. Does the school district use EPA's *Tools for Schools* program?

- Yes
- No

126b. If No, is some other IAQ management plan used?

- Yes
- No

126c. Has the District assigned IAQ responsibilities to a designated individual?

- Yes
- No

126c.1 If Yes, what is their job title?

Sr. Custodian

127. Does the school practice Integrated Pest Management (IPM)? (H)

- Yes
- No

127a. Is vegetation kept one foot away from the building?

- Yes
- No

127b. Are crevices and holes in walls, floors and pavement sealed or eliminated?

- Yes
- No

127c. Is there a certified pesticide applicator on staff?

- Yes
- No

127d. Are pesticides used in the building?

- Yes
- No

127d.1 If Yes, how are they typically applied?

- Spot treatment
- Area wide treatments

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Indoor Air Quality

Page Last Modified: 02/17/2023

127e. Are pesticides used on the grounds?

- Yes
- No

127e.1 If Yes, was an emergency exemption granted by the Board of Education?

- Yes
- No

128. Does the school have a passive radon mitigation system installed (was built with radon resistant features)?

(H)

- Yes
- No

128a. Has the facility been tested for the presence of radon?

- Yes
- No

128b. Were any of the results of the test greater than or equal to 4 picocuries per liter (pCi/L)?

- Yes
- No

128c. If Yes, did the school take steps to mitigate the elevated radon levels?

- Yes, active mitigation system installed
- Yes, passive mitigation system made active
- Yes, ventilation controls (HVAC) adjusted
- Yes, other (describe)
- No action taken

128c.1 Describe other actions taken to mitigate elevated radon levels:

(No Response)

2022 BUILDING CONDITION SURVEY - 2022 - 0-005-BellowsAnnex

Emergency Shelter

Page Last Modified: 02/17/2023

Emergency Shelter

129. Does this building serve as an emergency shelter?

Yes

No